



#### NOTES:

1. Inlet tops shall be set approximately 3" below the general surface of the ground, or as otherwise ordered. The ground surface within an area approximately 2' outside inlet top shall be replaced with Asphaltic Concrete Paving or 6" Reinforced Concrete Riprap, Item 601.04 (3).
2. The backfilling within the proposed paved areas shall be well tamped in layers not exceeding 4" thickness loose measurement, or backfilled with an approved granular material.

This drawing previously AA-S64

 STORMWATER PROGRAM MANAGER	
 ADMINISTRATOR	
12/15/93 APPROVED	REVISED

CATCH BASIN  
24" DIAMETER

CITY OF COLUMBUS		
DEPARTMENT OF PUBLIC UTILITIES		
DIVISION OF SEWERAGE & DRAINAGE		
STANDARD CONSTRUCTION DRAWING		
DR. W.C.K.	SHEET 1	FILE NO.
CK. _____	OF 1	AA-S131